



Bulk Energy Storage Resource Case Study – Update with the 2016 LTPP Assumptions

Shucheng Liu
Principal, Market Development

2016-2017 Transmission Planning Process Stakeholder Meeting
February 28, 2017



Purpose of the ISO bulk energy storage case study

- To assess a bulk storage resource's ability to reduce
 - production cost
 - renewable curtailment
 - CO2 emission
 - renewable overbuild to achieve the RPS target
- To analyze the economic feasibility of the bulk storage resource
- To consider the locational benefits of known potential bulk energy storage locations in ISO footprint

History of the bulk energy storage studies

- Initial study with 40% RPS was conducted in the 2015-2016 planning cycle¹
- It was then updated with a 50% RPS portfolio and some other changes²
- This is another update of the study with new assumptions and two sizes of bulk energy storages

^[1] <http://www.aiso.com/Documents/Board-Approved2015-2016TransmissionPlan.pdf>

^[2] <http://www.aiso.com/Documents/BulkEnergyStorageResource-2015-2016SpecialStudyUpdatedfrom40to50Percent.pdf>

Study Assumptions

Summary of study assumptions

- This study is based on the Default Scenario of the CPUC 2016 LTPP/TPP Assumptions and Scenarios³
- There are some major changes in the assumptions compared to the study with 50% RPS in 2015-2016 TPP
 - Retirement of non-dispatchable generation resources
 - Dispatchability of CHP resources
 - Lower load forecast and higher Additional Achievable Energy Efficiency (AAEE)
 - Lower RPS energy
 - Higher renewable curtailment prices

^[3] Reference: <http://docs.cpuc.ca.gov/PublishedDocs/Efile/G000/M162/K005/162005377.PDF>

Comparison of assumptions that may affect the results of this study notably

Assumption	This Study	2015-2016 TPP 50% RPS Study
Changes in non-dispatchable generation resources	Diablo Canyon nuclear plant (2,300 MW) is retired 2,786 MW CHP in operation	Diablo Canyon in operation 4,684 MW CHP in operation
Dispatchability of CHP resources*	50% of the 2,786 MW CHP is dispatchable	All 4,684 MW CHP is non-dispatchable
California Load forecast	64,009 MW 1-in-2 No AAEE non-coincident peak load 301,480 GWh energy	70,763 MW 1-in-2 No AAEE non-coincident peak load 322,218 GWh energy
California AAEE*	9,418 MW non-coincident peak impact 39,779 GWh energy CEC provided hourly profiles that usually have higher values in the late afternoon and early evening	5,713 MW non-coincident peak impact 24,535 GWh energy No hourly profile, offsetting load proportionally to the hourly load values

Comparison of assumptions that may affect the results of this study notably (cont.)

Assumption	This Study	2015-2016 TPP 50% RPS Study
CA RPS portfolio	36,776 MW installed capacity 110,288 GWh energy	40,986 MW installed capacity 125,307 GWh energy
Price of renewable generation curtailment*	-\$15/MWh for the first 200 GWh, -\$25/MWh for additional 12,400 GWh and -\$300/MWh thereafter	-\$300/MWh for all curtailment
Hydro condition	2005 hydro generation	2005 hydro generation
ISO maximum net export capability	2,000 MW	2,000 MW

Additional sensitivity analyses will be conducted to address the uncertainties in some of the assumptions.

- Because of the uncertainties in some of the assumptions, the ISO will conduct additional sensitivity analyses on at least the following assumptions
 - Dispatchability of CHP resource
 - Level of AAEE
 - Prices of renewable curtailment

Other assumptions

- Most of other assumptions for California are consistent with that in the study with 50% RPS in 2015-2016 TPP, including
 - Allowing renewable to provide load following-down up to 50% of the requirement
 - Enforcing a CAISO-wide frequency response requirement
- Assumptions for outside California are from the TEPPC 2026 Common Case v1.5 (October 21, 2016 release)

Study Approach


Study approach

- Analyzing two renewable build baselines, with and without a new bulk energy storage resource,
 - No overbuild of renewable resources
 - Overbuilding renewables to achieve 50% RPS target
- Overbuilding only solar or wind to explore the benefits of more diversified RPS portfolios
- Modeling two bulk energy storage sizes, 500 MW and 1,400 MW, separately

Definition of the study cases and expected takeaways

**No Renewable
Overbuild**

**With Overbuild to
Achieve 50% RPS**



This study quantifies

- reduction of production cost, renewable curtailment and CO2 emission,
- quantity and cost of renewable overbuild
- cost and market revenue of the bulk storage resource

It does not quantify

- transmission impact

Assumptions of the 500 MW new pumped storage resource, which represents the bulk energy storage

Item	Value
Number of units	2
Max pumping capacity per unit (MW)	300
Minimum pumping capacity per unit (MW)	75
Maximum generation capacity per unit (MW)	250
Minimum generation capacity per unit (MW)	5
Pumping ramp rate (MW/min)	50
Generation ramp rate (MW/min)	250
Round-trip efficiency	83%
VOM Cost (\$/MWh, pumping and generation)	1.5
Maintenance rate	8.65%
Forced outage rate	6.10%
Upper reservoir maximum capacity (GWh)	8
Upper reservoir minimum capacity (GWh)	2
Interval to restore upper reservoir water level	Monthly
Pump technology	Variable speed
Reserves can provide in generation and pumping modes	Regulation, spinning and load following
Reserves can provide in off modes	Non-spinning
Location	Southern California

Assumptions of the 1,400 MW new pumped storage resource

Item	Value
Number of units	4
Max pumping capacity per unit (MW)	422
Minimum pumping capacity per unit (MW)	75
Maximum generation capacity per unit (MW)	350
Minimum generation capacity per unit (MW)	5
Pumping ramp rate (MW/min)	50
Generation ramp rate (MW/min)	250
Round-trip efficiency	83%
VOM Cost (\$/MWh, pumping and generation)	1.5
Maintenance rate	8.65%
Forced outage rate	6.10%
Upper reservoir maximum capacity (GWh)	18.8
Upper reservoir minimum capacity (GWh)	2
Interval to restore upper reservoir water level	Monthly
Pump technology	Variable speed
Reserves can provide in generation and pumping modes	Regulation, spinning and load following
Reserves can provide in off modes	Non-spinning
Location	Southern California

Assumptions for revenue requirements and RA revenue calculation

Item	Generation & Transmission Costs (2016\$/kW-year) ^[4]	NQC Peak Factor ^[5]	RA Revenue (\$/kW-year) ^[6]
Large Solar In-State	242.19	47%	16.53
Large Solar Out-State	183.17	47%	16.53
Small Solar In-State	334.80	47%	16.53
Solar Thermal In-State	551.55	90%	31.66
Wind In-State	239.14	17%	5.98
Wind Out-State	223.88	45%	15.83
Pumped Storage In-State	407.91	100%	35.18

^[4] Draft2017 IRP Assumptions

http://www.cpuc.ca.gov/uploadedFiles/CPUC_Website/Content/Utilities_and_Industries/Energy/Energy_Programs/Electric_Power_Procurement_and_Generation/LTPP/DRAFT_RESOLVE_Inputs_2016-12-21.xlsx

^[5] <https://www.caiso.com/Documents/2012TACAreaSolar-WindFactors.xls> and <https://www.wecc.biz/Reliability/2024-Common-Case.zip>


^[6] CPUC 2015 RA Report <http://www.cpuc.ca.gov/WorkArea/DownloadAsset.aspx?id=6442452221>

Definition of the study cases


Case	Definition
A	Base Case, no pumped storage and no renewable overbuild
B500	Base Case plus a 500 MW pumped storage resource
B1400	Base Case plus a 1,400 MW pumped storage resource
C	Base Case with solar overbuild
D	Base Case with wind overbuild
E500	Base Case with solar overbuild and a 500 MW pumped storage resource
E1400	Base Case with solar overbuild and a 1,400 MW pumped storage resource
F500	Base Case with wind overbuild and a 500 MW pumped storage resource
F1400	Base Case with wind overbuild and a 1,400 MW pumped storage resource

Summary of Study Results

Capacity of renewable overbuild to achieve the 50% RPS target




California renewable generation curtailment




Renewable curtailment price is assumed as $-\$15/\text{MWh}$ for the first 200 GWh and $-\$25/\text{MWh}$ for additional 12,400 GWh.

California CO2 emission (50% RPS)




CA CO2 Emission includes the CO2 emission from net import

WECC annual production cost




Production cost includes start-up, fuel and VOM cost, but not CO2 cost.

Levelized annual revenue requirements of renewable overbuild and the pumped storage resources



Cost of the 1,400 MW pumped storage is discounted by 20% based on economies of scale assumption

Pumped storage levelized annual revenue requirements and net market revenues of 2026



Net Market Revenue is revenue from energy, reserves and load following minus cost of energy and operation

Summary of annual results by case

Case	No Pumped Storage			500 MW Pumped Storage			1,400 MW Pumped Storage		
	A	C	D	B500	E500	F500	B1400	E1400	F1400
Renewable Curtailment (GWh)	737	793	743	601	646	612	466	496	474
Curtailment Frequency (hours)	292	320	305	251	268	253	211	219	207
CA CO2 Emission (MM-ton)	26.83	26.75	26.72	26.39	26.33	26.34	25.91	25.89	25.88
CA CO2 Emission (\$million)	606	604	604	596	595	595	585	585	585
Production Cost (\$million)									
WECC	14,541	14,519	14,514	14,525	14,503	14,502	14,499	14,484	14,483
CA	2,999	2,989	2,986	2,952	2,945	2,946	2,900	2,898	2,897
Renewable Overbuild and Pumped Storage Capacity (MW)									
Solar		275			231			179	
Wind			257			220			166
Pumped Storage				500	500	500	1,400	1,400	1,400
Levelized Annual Revenue Requirement of Renewable Overbuild and Pumped Storage (\$million/year)									
Solar		62.11			52.17			40.43	
Wind			58.89			50.41			38.04
Pumped Storage				186.37	186.37	186.37	407.61	407.61	407.61
Sum		62.11	58.89	186.37	238.54	236.78	407.61	448.04	445.65
Pumped Storage Net Market Revenue (\$million)				48.91	49.35	49.03	92.47	93.81	93.20

Notes:

1. Renewable curtailment price is assumed as -\$15/MWh for the first 200 GWh and -\$25/MWh for additional 12,400 GWh.
2. CA CO2 Emission includes the CO2 emission from net import.
3. CO2 cost is \$22.59/M-ton.
4. Production cost includes start-up, fuel and VOM cost, but not CO2 cost.
5. Net Market Revenue is revenue from energy, reserves and load following minus cost of energy and operation.

Findings of system benefits

- Compared to the study with 50% RPS in 2015-2016 TPP, results of this study show significantly lower renewable curtailment, mainly due to
 - Retirement of Diablo Canyon and non-dispatchable CHP resources
 - Dispatchability of 50% of CHP resources
 - Lower load forecast together with higher AAEE, and the resulted lower renewable energy needed to achieve the 50% RPS target

Findings of system benefits (cont.)

- Because of low renewable curtailment, the effectiveness of the pumped storage resources in reducing renewable curtailment, CO2 emission and production costs is limited
- Besides lower curtailment, the net market revenues of the pumped storages are also affected by the higher renewable curtailment prices

Findings of system benefits (cont.)

- The net market revenue of the pumped storage resources provides only a portion of the levelized annual revenue requirements
- Developing pumped storage resources would need other sources of revenue streams, which could be developed through policy decisions

Findings of system benefits (cont.)

- The following annual system cost reductions (benefits) are not included in the net market revenue, but may be attribute to the pumped storage resources

Case	500 MW Pumped Storage		1,400 MW Pumped Storage	
	E500	F500	E1400	F1400
CA CO2 Emission (\$million)	-9.45	-8.50	-19.25	-18.79
Production Cost (\$million)				
WECC	-15.30	-11.96	-35.03	-30.96
CA	-44.05	-39.59	-91.49	-89.01
Levelized Annual Revenue Requirement of Renewable Overbuild (\$million/year)				
Solar	-9.94		-21.68	
Wind		-8.48		-20.85

Next steps

- The results of the study are sensitive to the assumptions, especially those listed in the tables on slide 6 and 7
- There are uncertainties in some of these assumptions
- The conclusions about the benefits and costs of the pumped storage resources could change should the assumptions change in the future
- The ISO will conduct sensitivity analyses at least on
 - Dispatchability of CHP resource
 - Level of AAEE
 - Prices of renewable curtailment